

Flameproof, Increased Safety, Dust Protection

15 mm

'G' Approx



















Elastomeric Exd Flameproof and Exe Increased Safety seal on cable outer sheath

127.0

142.0

Rounded Cable entry to prevent cable damage

The 501/421 dual certified Exe/Exd cable gland is intended for use on non-armoured elastomer and plastic insulated cables. This cable gland may be used with braided cables where the braid and outer sheath pass into the enclosure The braid must then be suitably terminated inside the enclosure. For Exd applications, the cable must be suitable in compliance with with BS EN 60079-14.

Cable Gland Selection Table **Hexagon Dimensions** Outer Sheath 'B' Size Ref. Standard Seal Alternative Seal (S) 'G' NPT* Standard 2K M16 3.2 8.0 23.5 19.0 21.2 Os M20² 1/2" 3.2 8.0 23.8 24.0 26.5 Ω 1/2" M20² 6.5 11.9 23.8 24.0 26.5 Α M20 3/4" or 1/2" 10.0 14.3 9.0 13.4 24.8 30.0 32.5 В M25 1" or ¾" 13.0 20.2 9.5 15.4 25.8 36.0 39.5 C 1¼" or 1" M32 19.5 26.5 15.5 21.2 29.2 46.0 50.5 C2 M40 1½" or 1¼" 25.0 32.5 30.5 55.0 60.6 22 28 D 44.4 / 42.3¹ M50 2" or 11/2" 31.5 27.5 34.8 40.4 65.0 70.8 Е M63 2½" or 2" 42.5 56.3 / 54.3¹ 39 38.2 80.0 88.0 46.5 M75 3" or 21/2" 54.5 $68.2 / 65.3^{1}$ 49.5 58.3 40.5 95.0 104.0 G M80 3½″ 67.0 73.0 41 115.0 106.4 Н M90 3½″ 67.0 77.6 41.0 115.0 130.0

All dimensions in millimetres (except * where dimensions are in inches)

Os - F size metric entry threads are 1.5mm pitch as standard, 15mm length of thread G - J size metric entry threads are 2mm pitch as standard, 20mm length of thread

4"

M100

91.6

77.0

Technical Data					
Ingress Protection	IP66, IP67 and IP68 (30 metres for 7 days, special conditions may apply) to IEC/EN 60529 and NEMA 4X				
Deluge Protection	Deluge Protection to DTS01				
Operating Temperature	-60°C to +100°C				
ATEX/IECEx					
ATEX/IECEx Protection Class	Ex II 2GD Ex db IIC Gb; Ex eb IIC Gb; Extb IIIC Db				
ATEX Certificate No	CML 19ATEX1167X				
IECEy Certificate No.	CMI 19 0045X				

ATEX/IECEx Protection Class	Ex II 2GD Ex db IIC Gb; Ex eb IIC Gb; Extb IIIC Db
ATEX Certificate No	CML 19ATEX1167X
IECEx Certificate No	CML 19.0045X
Construction & Test Standards	IEC/EN 60079-0, IEC/EN 60079-1, IEC/EN 60079-7 and IEC/EN 60079-31
Marine Approvals	DNV: TAE0000BS
Additional Certifications	EAC: RU C-GB.AA87.B.00430 Inmetro: IEx 14.0272X KCs: KTL 17-KA4BO-0120X to 0128X India: PESO P450038 China: CNEx17 2858X

N	EC	/	C	E	C

	NEC / CEC					
1	NEC Protection Class					
Class I, Div.2 Groups ABCD; CEC Protection Class Class II Div.2, Groups EFG; Class III Ex db IIC Gb; Ex eb IIC Gb		Class II Div.2, Groups EFG; Class III				
	c CSA us Certificate Number	CSA1015065				
	Construction & Test Standards	UL 60079-0, UL 60079-7, UL 60079-31, CSA 22.2 No: 60079-0, CSA 22.2 No: 60079-1, CSA 22.2 No: 60079-7, CSA 22.2 No: 60079-31, UL514B; UL1203; UL 2225				

HKE-DS-501/421-V3 July 2020

¹ Smaller value is applicable when selecting reduced NPT entry option.

² Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable outer sheath diameter is 10.9mm

Ordering Information							
Format for ordering is as follows: Alternative Seal (S), add suffix S to ordering information							
Cable Gland Type	Size	Thread	Material	(Optional)			
501/421	С	M32	Brass	S			
501/421	С	11/4" NPT	Brass	S			

Order Example: 501/421 C M32 Brass S



